



# Improving Cost Efficiency in Offshore Wind Through Optimal Overplanting

Study for the Bundesverband der Windenergie Offshore (**BWO**) and the Bundesverband der Energie- und Wasserwirtschaft (**BDEW**)

12 March 2026

English convenience translation

Study authors:

Dr. Matthias Janssen

Gregor Braendle ([gregor.braendle@frontier-economics](mailto:gregor.braendle@frontier-economics))

Laura Coordt

Lia Alscher



We advise industrial clients, trade associations and public sector clients across Europe...

... with extensive project experience in the field of electricity market design

Examples

**FOUNDED IN 1999...**

...and continuing to grow

**70 COUNTRIES**

Project experience in over 70 countries

**36 LANGUAGES**

Spoken by our employees


**340+ ECONOMISTS**

across 9 European offices



[Link to the Study](#)

Client:



[Link to the Study](#)

Client:



[Link to the Study](#)

Client:



[Link to the Study](#)

Client:



# Executive Summary



## Objective and Approach

- Background: Overplanting of offshore wind farms (OWFs) – i.e. lower grid connection capacity relative to installed wind capacity — is being discussed as a tool for efficiency. It increases the utilisation of the grid connection and can reduce system costs but leads to curtailment during periods of peak generation.
- Objective: **Analysis of the economically optimal overplanting** of offshore wind farms relative to grid connection systems (grid connection).
- Approach: **modelling the combination of OWFs and grid connection capacity that minimises the economic costs (investment and capital costs minus electricity revenues)** for four offshore areas and two expansion scenarios.



## Results

**Economically optimal overplanting lies in the range between 5 to 10%**, depending on the area and . The associated curtailment amounts to approximately 3 to 4%.

The optimal level of overplanting **depends on the generation profile, the grid connection length, and the ratio between OWF and grid connection costs**. Given this, future market developments could also lead to a higher or lower optimal overplanting.

The commercially (firm-level) optimal **level of overplanting** is around **2.5 to 5%**. From the perspective of an OWF, there are therefore already incentives for overplanting, albeit to a lesser extent than what is economically optimal.



## Conclusions

**Overplanting is systemically beneficial to a certain extent** and can enhance the efficiency of offshore expansion. A blanket requirement or one set too high, by contrast, would generate additional economic costs.

**The optimal level of overplanting depends on the location and costs**. If overplanting is made mandatory, it should be based on site characteristics (generation profile, distance, grid connection costs) and relative cost ratios.

Economically optimal overplanting **detracts from the commercial prospects of the OWF operator**, which could necessitate a compensation mechanism.




# Agenda

#	Topic	Slide
1	Background and Study Objective	5
2	Modelling Approach and Assumptions	9
3	Results	14
4	Conclusions	26

# Agenda


#	Topic	Slide
<b>1</b>	<b>Background and Study Objective</b>	<b>5</b>
2	Modelling Approach and Assumptions	9
3	Results	14
4	Conclusions	26

# Germany's offshore wind expansion is currently caught between ambition and reality



Sources: [WindGuard - Status des Offshore-Windenergieausbaus Jahr 2025](#), [NEP 2025 \(1.Entwurf\)](#), [Danish Energy Agency \(2025\) Technology Brief](#),


# The responsible planning authority (BSH) therefore proposes limited grid connections , i.e. “overplanting” in connection with “curtailment” during peak wind hours



## BSH's proposals in FEP 2025 to increase grid utilisation

### Focus on Zones 4 and 5:


- **Reduce grid connection capacity relative to wind farm capacity (“overplanting” of 20%)**
- Redesign of the sites with lower power density to reduce wake effects
- Increase in the transmission capacity of grid connection from the current 2 GW to 2.2 GW
- **Achieve a reduction of five grid connection systems compared to the Network Development Plan (NDP) 2037/2045.**



# BWO and BDEW commissioned Frontier Economics to contribute to the ongoing discussion by analysing the economic effects of overplanting



- **Quantitative analysis of optimal overplanting levels** from an economic and offshore wind farm perspective.




- **Sensitivity analysis** to test the robustness of the results and identify the **factors that influence optimal overplanting.**

# Agenda

#	Topic	Slide
1	Background and Study Objective	5
<b>2</b>	<b>Modelling Approach and Assumptions</b>	<b>9</b>
3	Results	14
4	Conclusions	26

# Model-based approach: we minimise infrastructure costs while considering the value of the electricity produced



	Economic Optimum	Firm-level Optimum OWF Perspective
OWF Capacity	Optimised*	Optimised*
Grid connection Capacity (up to grid connection point)	Optimised*	Exogenously specified
Min. electricity volume	Exogenously specified	No constraint

The model optimises infrastructure investments to minimise integration costs

$$\begin{array}{c}
 \text{OWF costs} \\
 \text{+} \\
 \text{Grid connection costs} \\
 \text{-} \\
 \text{Electricity sales revenue} \\
 \text{=} \\
 \text{Integration cost}
 \end{array}$$

Excluded from the OWF perspective



**“Integration cost” = total costs less electricity sales revenue:**  
 Remaining economic costs of integrating offshore wind. The ratio of OWF capacity to grid connection capacity that minimises integration cost determines the **optimal level of overplanting**.

\*To enable the most accurate optimisation possible, we assume that grid connection and OWF capacities can vary continuously (the optimum abstracts from real-world standardisation, such as a 2 GW grid connection system or a 22 MW wind turbine).





\*\* As the analysis considers entire areas, we assume the average distance to all grid connection points within a given area.

\*\*\* Prices at the grid connection point. The analysis does not consider the AC grid:(1) AC grid costs are not included in the modelling; i.e. grid costs include grid connection up to injection into the AC grid.(2) Curtailment due to (local) AC grid congestion, and its effect on the optimal level of overplanting, is not considered.

# We are analysing four reference areas for the currently planned expansion (“baseline scenario”) and an optimised scenario with lower power density



# Assumptions from the Fraunhofer IWES preliminary study: optimised expansion changes generation profiles and full-load hours




Source: Frontier Economics based on Fraunhofer IWES

\*The generation profiles reflect full-load hours after accounting for the availability of OWFs. Availability is based on Monte Carlo simulations by Fraunhofer IWES. We use a single time series (one one-year simulation run), with the average annual availability of the wind farms, including the grid connection stations, amounting to 93–94% depending on the area and scenario.

# Overview of cost assumptions: the level of grid connection costs strongly depends on the distance to the grid connection point

## Annualised costs\* for an offshore system without overplanting (2 GW OWF + 2 GW grid connection)




\*Costs include CAPEX, OPEX and cost of capital.

# Agenda

#	Topic	Slide
1	Background and Study Objective	5
2	Modelling Approach and Assumptions	9
<b>3</b>	<b>Results</b>	<b>14</b>
4	Conclusions	26


# Example results N-12 in the baseline scenario: the model optimum shows that a certain degree of overplanting is efficient from an economic perspective

## Modelling the economic optimum



# A deviation from the optimum leads to higher economic integration cost


## Modelling the economic optimum...



2  
No overplanting (0%)


1  
Optimal overplanting (7.2%)

3  
Excessive mandatory overplanting (20%)




# Complete results: the optimal economic level of overplanting for the areas considered in the baseline scenario ranges from 6.1 to 8.9%


Baseline scenario




# Optimised scenario: higher full-load hours tend to lead to a lower optimal level of overplanting




# The location of the grid connection point in the network development plan (NDP) impacts the optimal level of overplanting for an area



# Costs and revenues in the baseline scenario: high full-load hours and shorter grid connection length lead to lower economic integration cost









# Economic costs decline in the optimised scenario



# Assumptions and area characteristics significantly influence optimal overplanting

## The charts show optimal overplanting as a function of...



\*Average value of onshore and offshore CAPEX; \*\* the total distance from the OWF to the grid connection point is shown here. In the sensitivity analysis, only the onshore route length varies.



# A higher level of overplanting is efficient from an economic perspective than is commercially viable for OWF operators


Baseline scenario

Optimised scenario


**N-10 (371 km grid connection)**

Not profitable  
8.9%


**N-12 (303 km grid connection)**






**N-17+20 (617 km grid connection)**



**N-19 (387 km grid connection)**



Not profitable  
10.2%




# Comparison of cost and revenue: the business case for OWF operators deteriorates under the optimal economic level of overplanting

Example N-12  
Baseline  
scenario


Costs and revenue at the commercially optimal level: 2.5% overplanting

Change in costs and revenue from overplanting to the economic optimum (7.2%):

  
Economic perspective




  
OWF operator perspective



Change in costs  
(€/MWh<sub>el</sub>)

Change in costs  
(€/MWh<sub>el</sub>)



Grid connection costs decline under the optimal economic level of overplanting; overall, this results in lower economic costs

Operators bear higher OWF costs, but do not benefit from savings in grid connection costs → weaker commercial outcome

# Agenda

#	Topic	Slide
1	Background and Study Objective	5
2	Modelling Approach and Assumptions	9
3	Results	14
<b>4</b>	<b>Conclusions</b>	<b>26</b>

# Key results and conclusions



**5 to 10%**


economic  
overplanting

- **Overplanting** is efficient from an economic perspective up to a certain point because it reduces costs
- The **optimal economic level of overplanting** for the areas considered is **5 to 10%**
- An **excessively high mandatory overplanting requirement (e.g. 20%)** leads to **additional economic costs** under the assumptions used in this study



The optimal economic  
level of overplanting is

**site-specific**



- The optimal economic level of overplanting depends on
  - the characteristics of the respective site
  - assumptions on costs and price developments
- When multiple sensitivities are combined or possible market developments are taken into account, it may also be higher or lower than 5 to 10%
- A **mandatory overplanting requirement (e.g. 20%)** does not do justice to this



**3 to 5%**

Firm-level optimal  
overplanting

- There are also incentives for overplanting from the OWF perspective: **3 to 5%** for the areas considered
- An overplanting requirement set well above the **economic optimum therefore worsens the OWF business case** → a **compensation mechanism** may be required

# Limitations of the study and areas for further analysis

## Assumptions subject to uncertainty



- We do not consider **onshore grid costs and congestion** beyond the costs of the onshore connection line. In practice, structural grid congestion could limit offshore wind potential and increase the optimal level of overplanting.
- **Capture prices for offshore wind** and the ratio of OWF to grid connection costs are key factors for the optimal level of overplanting. Their future development is uncertain.
- The values for optimal overplanting identified in the study are based on **grid connection lengths up to the planned grid connection points** in the NDP. The choice of grid connection point (and thus the length of the onshore cable) is a separate optimisation task for the TSOs and may still change – and with it the optimal level of overplanting for individual areas.

## Comprehensive optimisation of offshore wind is needed



Overplanting can be a **useful tool for improving the efficiency** of offshore wind – but it is not the only one::

- **Increasing wind yield** by reducing power density (including through international cooperation).
- **Focusing on energy delivered** rather than purely on capacity targets (e.g. 70 GW).
- Measures to **de-risk** projects and achieve economies of scale in production in order to reduce costs.
- Analysis of further measures beyond direct use of wind energy in the power system, e.g. **offshore sector coupling**, where transport of **hydrogen** could reduce costs.



## **DR. MATTHIAS JANSSEN**

matthias.janssen@frontier-economics.com

<https://www.linkedin.com/in/matthias-janssen/>







## **GREGOR BRAENDLE**

gregor.braendle@frontier-economics.com

<https://www.linkedin.com/in/gregor-braendle/>

Frontier Economics Ltd is a member of the Frontier Economics Network, which consists of two separate companies based in Europe (Frontier Economics Ltd) und Australia (Frontier Economics Pty Ltd). Both companies are independently owned, and legal commitments entered into by one company do not impose any obligations on the other company in the network. All views expressed in this document are the view of Frontier Economics Ltd.

# Overview of the key assumptions in the model

	INPUT	ASSUMPTIONS			SOURCES
Areas + Wind profiles	Areas with installed capacity and hourly wind profiles	Outputs from the Fraunhofer IWES study “International Optimization of Full Load Hours in the German Bight” for weather year 2012: <b>energy yields</b> by area and scenario, <b>availability</b> based on Monte Carlo simulations, of which we use one simulation run in each case			<a href="#">Fraunhofer IWES (2026)</a>
Costs 	 OWF	<b>CAPEX</b> (logistics costs, soft costs, material costs): 3.4m €/MW	<b>OPEX</b> : ~0.036m €/MW (1.1% CAPEX p.a.)	<b>Asset life</b> : 30 years	<a href="#">Fraunhofer IWES (2026)</a>
	 DC cable system*	<b>CAPEX</b> (2-GW-grid connection): Offshore: 6.0m €/km Onshore: 7.6m €/km	<b>OPEX</b> : 2.5% (CAPEX p.a.)	<b>Asset life</b> : 30 years (identical to OWF)	CAPEX: <a href="#">NEP 2023</a> , AC substation from ENTSO-E ONDP (cost set 3); OPEX: <a href="#">ENTSO-E ONDP Methodology 2024</a>
	 Converter*	<b>CAPEX</b> : DC Offshore: 0.7m €/MW DC Onshore: 0.3m €/MW AC-Substation: 0.24m €/MW	<b>OPEX</b> : 1.5% (CAPEX p.a.)		
	Cost of capital	<b>3%</b> for grid connection components, <b>6%</b> for OWFs (real)			Grid: <a href="#">BNetzA (2024)</a> for new investments; OWFs: <a href="#">Fraunhofer ISE LCOE Study (2024)</a>
Prices	Hourly power prices	Modelled for target year 2045 based on weather year 2019			Frontier’s European energy model <a href="#">COMET</a>